


AUGUST, 2011

Day of Month	Flow cfs	Temp °F	Hydro kWh	Day of Month	Flow cfs	Temp °F	Hydro kWh	Day of Month	Flow cfs	Temp °F	Hydro kWh
1	6,084	84	444,717	12	4,404	78	460,731	23	2,452	78	296,661
2	5,828	82	411,822	13	4,464	77	418,576	24	2,219	78	269,996
3	2,991	83	348,898	14	4,148	77	439,941	25	1,151	79	180,940
4	3,412	83	371,268	15	4,134	78	454,169	26	1,203	79	186,738
5	3,413	83	390,844	16	4,202	78	442,232	27	1,235	78	179,918
6	3,658	84	404,358	17	4,386	79	427,413	28	1,162	74	176,827
7	3,603	83	398,036	18	4,392	79	429,567	29	1,456	75	178,819
8	3,672	83	411,574	19	4,333	79	423,237	30	1,480	75	195,367
9	3,954	82	415,915	20	4,565	80	413,476	31	1,132	75	189,744
10	4,096	79	421,040	21	4,354	79	328,959				
11	3,974	79	422,926	22	3,096	78					

	FLOW	TEMP	HYDRO (kWh)
TOTAL	104,653		10,534,709
AVERAGE	3,376	79.33	351,157
MAXIMUM	6,084	84.20	460,731



NOTES: TEMP shown in (°F) Fahrenheit, FLOW shown in (cfs) cubic feet per second, and HYDRO shown in (kWh) kilo watt hours.

Putting it in perspective: The average monthly use per home (kWh):

1,000

We generated enough to power this many homes during this month:

10,535

