




AUGUST, 2012

Day of Month	Flow cfs	Temp °F	Hydro kWh	Day of Month	Flow cfs	Temp °F	Hydro kWh	Day of Month	Flow cfs	Temp °F	Hydro kWh	
1	1,329	83	117,859	12	1,514	74	112,903	23	1,376	76	111,025	
2	1,548	83	125,184	13	1,694	75	116,891	24	1,601	76	112,540	
3	1,750	82	122,064	14	1,809	76	114,675	25	1,501	77	108,768	
4	1,405	83	117,381	15	1,521	77	114,703	26	1,783	77	111,677	
5	1,766	82	119,923	16	1,811	73	128,146	27	1,804	77	111,379	
6	1,166	81	104,580	17	1,675	75	122,470	28	1,588	78	106,709	
7	1,673	81	117,688	18	1,422	75	116,143	29	1,431	77	107,946	
8	1,601	81	112,833	19	1,503	75	116,898	30	1,754	77	117,225	
9	1,865	79	130,979	20	1,470	75	117,711	31	1,554	77	114,637	
10	1,637	76	115,930	21	1,753	75	120,338					
11	1,467	72	104,143	22	1,972	74	120,213					
FLOW			TEMP			HYDRO (kWh)						
TOTAL	49,743						3,591,563					
AVERAGE	1,605			77.40			115,857					
MAXIMUM	1,972			83.00			130,979					



NOTES: TEMP shown in (°F) Fahrenheit, FLOW shown in (cfs) cubic feet per second, and HYDRO shown in (kWh) kilo watt hours.

Putting it in perspective: The average monthly use per home (kWh):

1,000

We generated enough to power this many homes during this month:

3,592

