


Day of Month	Flow cfs	Temp °F	Hydro kWh	Day of Month	Flow cfs	Temp °F	Hydro kWh	Day of Month	Flow cfs	Temp °F	Hydro kWh
1	1,986	71	240,520	12	1,616	67	159,291	23	1,758	68	213,236
2	1,955	71	248,177	13	1,619	67	160,603	24	1,665	67	206,391
3	2,147	71	247,886	14	1,806	66	157,516	25	1,667	67	195,097
4	2,062	73	238,731	15	1,831	66	173,912	26	1,824	67	202,417
5	2,117	75	233,347	16	1,942	67	163,718	27	1,808	66	217,316
6	1,890	75	217,774	17	1,716	67	148,747	28	1,905	66	208,345
7	1,694	73	183,652	18	1,648	66	147,080	29	2,009	66	232,257
8	1,545	71	201,616	19	1,793	66	163,475	30	2,337	66	254,232
9	1,739	71	213,229	20	1,932	66	183,924				
10	1,865	69	214,451	21	1,466	67	192,712				
11	1,556	68	177,474	22	1,904	68	206,270				

	FLOW	TEMP	HYDRO (kWh)
TOTAL			6,003,396
AVERAGE	1,827	68.42	200,113
MAXIMUM	2,337	74.70	254,232



NOTES: TEMP shown in (°F) Fahrenheit, FLOW shown in (cfs) cubic feet per second, and HYDRO shown in (kWh) kilo watt hours.

Putting it in perspective: The average monthly use per home (kWh):

1,000

We generated enough to power this many homes during this month:

6,003



Total Hydro BTM (Behind the Meter)
Avoided Cost (Net)

5,316,441 kWh
\$387,611

